

# KRTC橘線廠站冷卻水循環水量

附件三

No.	車站	冰機規格	冰水循環水量 LPS	冰水保有水 量M <sup>3</sup>	冷卻水塔規 格	冷卻水循環水量 LPS	冷卻水保 有水量M <sup>3</sup>
1.	O01A	353kw x2	16,8 l/s x2	5.4	455kw x2	21.7 l/s x2	13.3
2.	O01B	353kw x2	16,8 l/s x2	5.4	455kw x2	21.7 l/s x2	13.3
3.	O02A	370kw x2	16,8 l/s x2	4.09	455kw x2	22.7 l/s x2	3.8
4.	O02B	370kw x2	16,8 l/s x2	3.11	455kw x2	22.7 l/s x2	20.8
5.	O04	300kw x4	14.1 l/s x4	5.4	365kw x4	18.1 l/s x4	13.3
6.	O5-01/02A	1164kw x4	55.62 l/s x4	41	1429kw x4	68.27 l/s x4	50
7.	O5-01/02D	684.5kw x4	32.7 l/s x4	30	841kw x4	40.15 l/s x4	29
8.	R10-01/02C	854kw x4	40.8 l/s x4	24	1049kw x4	50.1 l/s x4	37
9.	O06	423kw x4	20.2 l/s x4	17.8	545kw x4	26 l/s x4	23.9
10.	O07	388kw x4	18.5 l/s x4	16.3	500kw x4	23.9 L/S x 4	21.2
11.	O08	509.8kw x4	24.36 l/s x4	22.2	637kw x4	30.45 l/s x4	28.3
12.	O09	423kw x4	20.2 l/s x4	17.9	545kw x4	26 l/s x4	41
13.	O10	458kw x4	21.9 L/S x 4	19.2	591kw x4	28.2 L/S x 4	47.2
14.	O11A	352kw x2	16.8 l/s x2	3.4	455kw x2	21.7 l/s x2	7.8
15.	O11B	317kw x2	15.2 l/s x2	3	409kw x2	19.5 l/s x2	8.7
16.	O12	423kw x4	20.2 l/s x4	18.5	545kw x4	26 l/s x4	39.5
17.	O13	458kw x4	21.8 l/s x4	15	595kw x4	28.4 l/s x4	30
18.	O14A	423kw x2	20.2 l/s x2	10	550kw x2	26.3 l/s x2	15
19.	O14B	423kw x2	20.2 l/s x2	10	550kw x2	26.3 l/s x2	20
20.	BSS3	NA	NA	NA	505.8kw x2	9.6L/s	5
21.	MD土木軌道廠	120kw x2	5.8 l/s x2	2.3	NA	NA	NA
22.	MD車務中心	187kw x2	8.97 l/s x2	1.2	243kw x2	11.6 l/s x2	2.3
23.	MD管理中心	788kw x3	37.8l/s x3	83	1020kw x3	48.5l/s x3	42.5
24.	MD維修廠	525kw x3	25 l/s x3	85.5	613kw x3	31.8 l/s x3	108
25.	MD TSS	NA	NA	NA	255kw x2	12.2 l/s x2	1.8