

KRTC 紅線廠站冷卻水循環水量

附件二

No.	車站	冰機規格	冰水循環水量 LPS	冰水保有水 量M ³	冷卻水塔規 格	冷卻水循環水量 LPS	冷卻水保有 水量M ³
1.	R3	353kw x4	16.9 L/S x 4(67.6)	16	461kw x4	22 L/S x 4(88)	20
2.	R4	423kw x4	20.2 L/S x 4(80.8)	19	545kw x4	26 L/S x 4(104)	24
3.	R4A	353kw x4	16.9 L/S x 4(67.6)	16	455kw x4	21.7 L/S x 4(86.8)	20
4.	R5	318kw x4	15.2 L/S x 4(67.6)	15	409kw x4	19.5 L/S x 4(86.8)	18
5.	R6	528kw x4	25.2 L/S x 4(100.8)	24	681kw x4	32.5 L/S x 4(130)	33
6.	R7	353kw x4	16.8 L/S x 4(67.2)	16	455kw x4	21.7 L/S x 4(86.8)	20
7.	R8	616kw x4	29.4 L/S x 4(117.6)	28	797kw x4	38 L/S x 4(152)	36
8.	R9	616kw x4	29.4 L/S x 4(117.6)	28	780kw x4	38 L/S x 4(152)	36
9.	R11南站	388kw x4	23.9 L/S x 4(74)	30	500kw x4	23.9 L/S x 4(95.6)	13
10.	R12	423kw x4	20.16L/S x 4(80.64)	25	545kw x4	26 L/S x 4(104)	70
11.	R13	458kw x4	21.9 L/S x 4(87.6)	25	588kw x4	28.2 L/S x 4(112.8)	70
12.	R14	463kw x4	22.1L/S x 4(88.4)	13.7	593kw x4	114(28.5x4)	19
13.	R15	423kw x4	80.8(20.2x4)	11	545kw x4	104(26x4)	11.35
14.	R16	558kw x3	55(26.6x2)	27	720kw x3	70.8(34.3x3)	15.7
15.		851kw x3	80.16(40.6x3)	27	1098kw x3	103.4(52.3x3)	15.7
16.	BSS5	NA	NA	NA	362kw x2	19.3L/s(9.6x2)	10
17.	SD BSS1	NA	NA	NA	310.68kw x2	14.84 L/S	8
18.	SD TSS	NA	NA	NA	439.64kw x2	21 L/S x 2(36.9)	16
19.	SD工辦	211kw x3	10.08 L/S x 3	20	274kw x3	13.1 L/S x 3	16
20.	ND TSS	NA	NA	NA	358.38kw x2	16.88 L/S x2	16
21.	ND 工辦	211kw x3	10.08 L/S x 3	20	274kw x3	36.9 L/S	16
22.	OCC	844kw x2	40.32 L/S	4	1055kw x2	50.4 L/S	10
23.	ADM	880kw x3	41.6L/S x3	18.4	1093.7kw x3	104 L/S	20.5
24.	LD	175.8kw x2	8.39 L/S x3	8	1.5kw x2	10.1 L/S x3	9